



**PROFESSIONAL
OUTDOOR LIGHTING**



8165 E Kaiser Blvd. Anaheim, CA 92808
p. 714.282.2270
f. 714.676.5558

Report No: L081407507
Date: 9/9/2014



NVLAP LAB CODE 200927-0

Report No: L081407507

Report Prepared For: U.S.T.E. dba Vista Professional Outdoor Lighting
1625 Surveyor Ave. Simi Valley CA 93063

Model Number: 1057-XX-WF-B-30

Test: Electrical and Photometric tests

Standards Used: Appropriate part or all test guidelines were used for test performed:
IESNA LM79: 2008 Approved Methods for Electrical and Photometric Measurements of Solid-State Lighting Products
ANSI NEMA ANSLG C78.377: 2008 Specification of the Chromaticity of Solid State Lighting Products
ANSI C82.77:2002: Harmonic Emission Limits-Related Quality Requirements for Lighting Equipment

Description of Sample: Client submitted the sample. Catalog number is 1057-XX-WF-B-30 . Received in working and undamaged condition. No modifications were necessary.

Testing Condition: Fixture is tested with no special conditions.

Sample Arrival Date: 9/8/14

Date of Tests: 9/8/14 - 9/8/14

Seasoning of Sample: No seasoning was performed in accordance with IESNA LM-79.

Equipment List

| Equipment Used | Model No | Stock No | Calibration Due Date |
|-----------------------------------|------------|------------|----------------------|
| Chroma Programmable AC Source | 61604 | PS-AC02 | -- |
| Yokogawa Digital Power Meter | WT210 | MT-EL06-S1 | 01/04/15 |
| Xitron Power Analysis System | 2503AH | MT-EL01 | 01/09/15 |
| BK Precision DC Power Supply | 1747 | PSDC-04 | 01/08/15 |
| Fluke Digital Thermometer | 52k/J | MT-TP02-GC | 01/04/15 |
| LLI Type C Goniophotometer System | RMG-C-MKII | CD-LL04-GC | -- |
| LLI 2M Sphere | 2MR97 | CD-SN03-S2 | -- |
| LLI Spectroradiometer | SPR-3000 | MT-SC01-S2 | Before Use |

*All Results in accordance to IESNA LM-79-2008: Approved Method for the Electrical and Photometric Testing of Solid-State Lighting.

Test Summary

| | | |
|--|--|--|
| Manufacturer: | U.S.T.E. dba Vista Professional Outdoor Lighting | |
| Model Number: | 1057-XX-WF-B-30 | |
| Driver Model Number: | THOMAS RESEARCH PRODUCTS LED40W-054-C0700-D | |
| Total Lumens: | 2263.08 | |
| Input Voltage (VAC/60Hz): | 120.00 | |
| Input Current (Amp): | 0.23 | |
| Input Power (W): | 27.51 | |
| Input Power Factor: | 0.99 | |
| Current ATHD @ 120V(%): | 7% | |
| Current ATHD @ 277V(%): | 8% (0.11A, 27.2W, 0.91PF) | |
| Efficacy: | 82 | |
| Color Rendering Index (CRI): | 83 | |
| Correlated Color Temperature (K): | 3035 | |
| Chromaticity Coordinate x: | 0.4357 | |
| Chromaticity Coordinate y: | 0.4058 | |
| Ambient Temperature (°F): | 77.0 | |
| Stabilization Time (Hours): | 0:25 | |
| Total Operating Time (Hours): | 1:15 | |
| Off State Power(W): | 0.00 | |





FIG. 1 LUMINAIRE

*All Results in accordance to IESNA LM-79-2008: Approved Method for the Electrical and Photometric Testing of Solid-State Lighting.




| Wavelength | W/m ² nm | 440 | 0.0353 | 510 | 0.0646 | 580 | 0.1432 | 650 | 0.0981 | 720 | 0.0143 |
|------------|---------------------|-----|--------|-----|--------|-----|--------|-----|--------|-----|--------|
| 380 | 0.0026 | 450 | 0.0787 | 520 | 0.0757 | 590 | 0.1534 | 660 | 0.0794 | 730 | 0.0104 |
| 390 | 0.0008 | 460 | 0.0632 | 530 | 0.0844 | 600 | 0.1597 | 670 | 0.0619 | 740 | 0.0075 |
| 400 | 0.0005 | 470 | 0.0405 | 540 | 0.0934 | 610 | 0.1589 | 680 | 0.0471 | 750 | 0.0056 |
| 410 | 0.0012 | 480 | 0.0304 | 550 | 0.1041 | 620 | 0.1506 | 690 | 0.0359 | 760 | 0.0040 |
| 420 | 0.0050 | 490 | 0.0358 | 560 | 0.1156 | 630 | 0.1360 | 700 | 0.0260 | 770 | 0.0028 |
| 430 | 0.0145 | 500 | 0.0500 | 570 | 0.1286 | 640 | 0.1180 | 710 | 0.0196 | 780 | 0.0021 |

CRI & CCT

| | |
|-----|---------|
| x | 0.4357 |
| y | 0.4058 |
| u' | 0.2490 |
| v' | 0.5219 |
| CRI | 82.50 |
| CCT | 3035 |
| Duv | 0.00086 |

R Values

| | |
|-----|-------|
| R1 | 80.69 |
| R2 | 89.99 |
| R3 | 96.87 |
| R4 | 80.34 |
| R5 | 80.20 |
| R6 | 86.99 |
| R7 | 84.18 |
| R8 | 60.83 |
| R9 | 10.03 |
| R10 | 76.52 |
| R11 | 78.72 |
| R12 | 67.58 |
| R13 | 83.34 |
| R14 | 98.35 |



*All Results in accordance to IESNA LM-79-2008: Approved Method for the Electrical and Photometric Testing of Solid-State Lighting.



8165 E Kaiser Blvd. Anaheim, CA 92808
 p. 714.282.2270
 f. 714.676.5558

Report No: L081407507

Date: 9/9/2014



NVLAP LAB CODE 200927-0

Test Methods

Photometric Measurements - Goniophotometer

A Custom Light Laboratory Type C Rotating Mirror Goniophotometer was used to measure candelas(intensity) at each angle of distribution as defined by IESNA for the appropriate fixture type.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Spectral Measurements - Integrating Sphere

A Sensing Spectroradiometer SPR-3000, in conjunction with Light Laboratory 2 meter integrating sphere was used to measure chromaticity coordinates, correlated color temperature(CCT) and the color rendering index(CRI) for each sample.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Disclaimers:

This report must not be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST or any agency of Federal Government.

Report Prepared by : Wilson Khounlavong

Test Report Released by:

Test Report Reviewed by:

Jeff Ahn
 Engineering Manager

Steve Kang
 Quality Assurance

**Attached are photometric data reports. Total number of pages: 8*

*All Results in accordance to IESNA LM-79-2008: Approved Method for the Electrical and Photometric Testing of Solid-State Lighting.



8165 E. Kaiser Blvd. Anaheim, CA 92808
 p. 714.282.2270
 f. 714.676.5558

Photometric Test Report

IES FLOOD REPORT
PHOTOMETRIC FILENAME : L081407507.IES

DESCRIPTIVE INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST] L081407507
 [TESTLAB] LIGHT LABORATORY, INC.
 [ISSUE DATE] 9/9/2014
 [MANUFAC] U.S.T.E. DBA VISTA PROFESSIONAL OUTDOOR LIGHTING
 [LUMCAT] 1057-XX-WF-B-30
 [LUMINAIRE] 7"DIA X 12-1/2"H. LED FLOODLIGHT
 [MORE] CLEAR LENS
 [BALLASTCAT] THOMAS RESEARCH PRODUCTS LED40W-054-C0700-D
 [BALLAST] INPUT: 100-277VAC, 0.40A, 50/60HZ. OUTPUT: 18-54VDC, 700mA, 37.8W max
 [LAMPPOSITION] 0,0
 [LAMP CAT] N/A
 [OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
 [MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.
 [INPUT] 120VAC, 27.51W
 [TEST PROCEDURE] IESNA:LM-79-08

Note: Candela values converted from Type-C to Type-B

CHARACTERISTICS


| | |
|------------------------------|-----------------|
| NEMA Type | 6 H x 6 V |
| Maximum Candela | 1166 |
| Maximum Candela Angle | -33H -1V |
| Horizontal Beam Angle (50%) | 83.4 |
| Vertical Beam Angle (50%) | 54.6 |
| Horizontal Field Angle (10%) | 120.2 |
| Vertical Field Angle (10%) | 107.0 |
| Lumens Per Lamp | N.A. (absolute) |
| Total Lamp Lumens | N.A. (absolute) |
| Beam Lumens | 1768 |
| Beam Efficiency | N.A. |
| Field Lumens | 2160 |
| Field Efficiency | N.A. |
| Spill Lumens | 103 |
| Luminaire Lumens | 2263 |
| Total Efficiency | N.A. |
| Total Luminaire Watts | 27.51 |
| Ballast Factor | 1.00 |

IES FLOOD REPORT
PHOTOMETRIC FILENAME : L081407507.IES

AXIAL CANDELA

| DEG. | HOR. | DEG. | VERT. |
|-------|------|-------|-------|
| 90 | 0 | 90 | 0 |
| 85 | 4 | 85 | 4 |
| 75 | 10 | 75 | 10 |
| 65 | 58 | 65 | 58 |
| 55 | 177 | 55 | 177 |
| 47.5 | 368 | 47.5 | 368 |
| 42.5 | 484 | 42.5 | 484 |
| 37.5 | 1113 | 37.5 | 1113 |
| 33 | 1166 | 33 | 1166 |
| 29 | 1155 | 29 | 1155 |
| 25.5 | 1146 | 25.5 | 1146 |
| 22.5 | 1142 | 22.5 | 1142 |
| 19.5 | 1139 | 19.5 | 1139 |
| 17 | 1138 | 17 | 1138 |
| 15 | 1137 | 15 | 1137 |
| 13 | 1137 | 13 | 1137 |
| 11 | 1136 | 11 | 1136 |
| 9 | 1136 | 9 | 1136 |
| 7 | 1137 | 7 | 1137 |
| 5 | 1140 | 5 | 1140 |
| 3 | 1144 | 3 | 1144 |
| 1 | 1148 | 1 | 1148 |
| 0 | 1149 | 0 | 1149 |
| -1 | 1148 | -1 | 1148 |
| -3 | 1144 | -3 | 1144 |
| -5 | 1140 | -5 | 1140 |
| -7 | 1137 | -7 | 1137 |
| -9 | 1136 | -9 | 1136 |
| -11 | 1136 | -11 | 1136 |
| -13 | 1137 | -13 | 1137 |
| -15 | 1137 | -15 | 1137 |
| -17 | 1138 | -17 | 1138 |
| -19.5 | 1139 | -19.5 | 1139 |
| -22.5 | 1142 | -22.5 | 1142 |
| -25.5 | 1146 | -25.5 | 1146 |
| -29 | 1155 | -29 | 1155 |
| -33 | 1166 | -33 | 1166 |
| -37.5 | 1113 | -37.5 | 1113 |
| -42.5 | 484 | -42.5 | 484 |
| -47.5 | 368 | -47.5 | 368 |
| -55 | 177 | -55 | 177 |
| -65 | 58 | -65 | 58 |
| -75 | 10 | -75 | 10 |
| -85 | 4 | -85 | 4 |
| -90 | 0 | -90 | 0 |

AXIAL CANDELA DISPLAY




Maximum Candela = 1166 Located At Horizontal Angle =-33, Vertical Angle =-1

H - Horizontal Axial Candela

V - Vertical Axial Candela

ISOCANDELA CURVES



Maximum Candela = 1166 Located At Horizontal Angle =-33, Vertical Angle =-1
50% Maximum Candela = 583
10% Maximum Candela = 116.6