



**PROFESSIONAL
OUTDOOR LIGHTING**



NVLAP
NVLAP LAB CODE 200927-0



www.lightlaboratory.com

Photometric Test Summary - Vista 1059 Series

File No.	Catalog Number	Description	Test Voltage	Beam Angle (H/V)	Field Angle (H/V)	Total Lumens	Wattage	Efficacy	CRI	CCT
L081407412	1059-X-NS-30-G-MV-ND	LED Floodlight, NS Distribution	120VAC	11.6 / 11.6	22.5 / 22.5	5180.75	74.14	69.88	82	3148
L081407413	1059-X-MF-30-G-MV-ND	LED Floodlight, MF Distribution	120VAC	60.5 / 56.6	74.7 / 73.4	4971.86	74.13	67.07	81.7	3130
L081407414	1059-X-WF-30-G-MV-ND	LED Floodlight, WF Distribution	120VAC	82.8 / 62.9	123.1 / 115.2	4565.98	73.82	61.85	82	3202
L081407409	1059-X-NS-30-F-MV-ND	LED Floodlight, NS Distribution	120VAC	11.4 / 11.4	22.5 / 22.5	4280.52	59.49	71.95	82.2	3152
L081407410	1059-X-MF-30-F-MV-ND	LED Floodlight, MF Distribution	120VAC	60.3 / 56.4	74.8 / 73.5	4150.94	59.75	69.47	82	3132
L081407411	1059-X-WF-30-F-MV-ND	LED Floodlight, WF Distribution	120VAC	82.1 / 62.9	122.6 / 115.3	3932.52	59.38	66.23	82	3186
L081407406	1059-X-NS-30-E-MV-ND	LED Floodlight, NS Distribution	120VAC	11.6 / 11.6	22.6 / 22.6	3874.24	49.48	78.3	82.3	3135
L081407407	1059-X-MF-30-E-MV-ND	LED Floodlight, MF Distribution	120VAC	60.5 / 56.6	74.7 / 73.4	3744.26	49.5	75.65	82.3	3096
L081407408	1059-X-WF-30-E-MV-ND	LED Floodlight, WF Distribution	120VAC	83.2 / 54.3	123.5 / 111.7	3475.92	49.26	70.56	82.6	3162
L081407403	1059-X-NS-30-D-MV-ND	LED Floodlight, NS Distribution	120VAC	11.7 / 11.7	22.6 / 22.6	3558.74	48.1	73.99	82.6	3129
L081407404	1059-X-MF-30-D-MV-ND	LED Floodlight, MF Distribution	120VAC	60.5 / 56.6	74.8 / 73.4	3407.2	48.2	70.68	82.2	3106
L081407405	1059-X-WF-30-D-MV-ND	LED Floodlight, WF Distribution	120VAC	83.2 / 54.2	123.6 / 111.7	3198.96	47.88	66.82	82.6	3168
L081407401	1059-X-VNS-30-C-MV-ND	LED Floodlight, NS Distribution	120VAC	11.3 / 11.3	21.9 / 21.9	2792.88	74.08	37.7	81.8	3130
L081407402	1059-X-VNS-30-B-MV-ND	LED Floodlight, NS Distribution	120VAC	11.6 / 11.6	22.1 / 22.1	2459.9	59.69	41.21	82.1	3091

*LED Flood Report includes LM-79 Report, Report Summary, Axial Display, Isocandela.

Photometric Test Summary - Vista 1057 Series

File No.	Catalog Number	Description	Test Voltage	Beam Angle (H/V)	Field Angle (H/V)	Total Lumens	Wattage	Efficacy	CRI	CCT
L03148701	1057-X-NS-30-C-MV-ND	LED Floodlight, NS Distribution	120VAC	9.1 / 9.1	17.3 / 17.3	2825.26	42.68	66.19	81.9	3141
L081407508R01	1057-X-MF-30-C-MV-ND	LED Floodlight, MF Distribution	120VAC	52.5 / 43.3	65.7 / 61.3	2747.6	38.31	71.73	82	3015
L081407509	1057-X-WF-30-C-MV-ND	LED Floodlight, WF Distribution	120VAC	83.6 / 54.9	120.7 / 107.7	2774.58	38.14	72.75	82.1	3050
L081407505	1057-X-NS-30-B-MV-ND	LED Floodlight, NS Distribution	120VAC	9.2 / 9.2	18.1 / 18.1	2588.56	27.53	94.04	82.4	3015
L081407506R01	1057-X-MF-30-B-MV-ND	LED Floodlight, MF Distribution	120VAC	52.4 / 43.3	65.7 / 61.2	2213.54	27.55	80.34	82.3	3016
L081407507	1057-X-WF-30-B-MV-ND	LED Floodlight, WF Distribution	120VAC	83.4 / 54.6	120.2 / 107	2263.08	27.51	82.26	82.5	3035
L081407501	1057-X-VNS-30-A-MV-ND	LED Floodlight, VNS Distribution	120VAC	11.5 / 11.5	20.1 / 20.1	1684.96	38.28	44.01	81.7	3001
L081407502	1057-X-NS-30-A-MV-ND	LED Floodlight, NS Distribution	120VAC	9.2 / 9.2	18.1 / 18.1	1834.98	18.06	101.62	82.9	2994
L081407503	1057-X-MF-30-A-MV-ND	LED Floodlight, MF Distribution	120VAC	52.2 / 45.6	65.6 / 63	1602.68	18.08	88.63	82.7	2982
L081407504	1057-X-WF-30-A-MV-ND	LED Floodlight, WF Distribution	120VAC	83.4 / 54.7	120.2 / 107	1613.12	18.03	89.49	82.9	3018

*LED Flood Report includes LM-79 Report, Report Summary, Axial Display, Isocandela.