



**PROFESSIONAL
OUTDOOR LIGHTING**



Photometric Test Summary - Vista 1471 Series

File No.	Catalog Number	Description	Test Voltage	B-U-G Rating	Mounting Height	IES Classification	Total Lumens	Wattage	Efficacy	CRI	CCT
L091706901	1471-4Q-A	Bollard, 4 quadrant, 350mA	120VAC	B1-U3-G1	3	Type V	1634.2	23.91	68.35	81.7	2849
L091706902	1471-3Q-A	Bollard, 3 quadrant, 350mA	120VAC	B1-U2-G1	3	Type IV	1197.1	18.08	66.2	81.6	2872
L091706903	1471-2Q90-A	Bollard, 2 quadrant, 90° apart, 350mA	120VAC	B0-U2-G1	3	Type IV	744	11.83	62.88	84.2	3164
L091706904	1471-2Q180-A	Bollard, 2 quadrant, 180° apart, 350mA	120VAC	B1-U2-G1	3	Type IV	712.4	11.93	59.69	84	3143
L091706905	1471-1Q-A	Bollard, 1 quadrant, 350mA	120VAC	B0-U1-G1	3	Type IV	383.1	6.48	59.15	81.7	2895
L091706906	1471-4Q-B	Bollard, 4 quadrant, 500mA	120VAC	B1-U3-G1	3	Type V	2163.4	34.96	61.89	81.3	2917
L091706907	1471-3Q-B	Bollard, 3 quadrant, 500mA	120VAC	B1-U3-G1	3	Type IV	1540.5	26.34	58.48	81	2900
L091706908	1471-2Q90-B	Bollard, 2 quadrant, 90° apart, 500mA	120VAC	B0-U2-G1	3	Type IV	1050.3	17.81	58.97	81.7	2909
L091706909	1471-2Q180-B	Bollard, 2 quadrant, 180° apart 500mA	120VAC	B1-U2-G1	3	Type IV	984.4	17.77	55.38	81.3	2919
L091706910	1471-1Q-B	Bollard, 1 quadrant, 500mA	120VAC	B0-U2-G1	3	Type IV	504.5	9.16	55.08	81.5	2926